



KARNATAKA STATE FIRE AND EMERGENCY SERVICES



Office of the District Fire Officer, Sunkadakatte Fire Station, Machohalli,
Magadi Main Road, Bengaluru-560 091 ☎ 080-29554101.

No. 20/RFSCR/DFO/SKFS/2025

Date: 12-06-2025

"Annexure-2"

To,
The Authorized Signatory
M/S.Mari Gold International School,
Anchepalya, Kumbalagodu,
Bengaluru-560 074

§

Sir,

Sub : Issue of "Renewal Fire Safety Compliance Certificate" with respect to fire prevention, firefighting and evacuation measures maintained at "M/S. Mari Gold International School, Situated at Anchepalya, Kumbalagodu, Bengaluru-reg.

- Ref :** 1) CFO FSR No.329/FSR/CFO/BER/2021, Date:22-03-2021.
2)DFO RFSCR No.32/RFSCR/DFO/BFS/2024, Date:20-05-2024.
3) Your request letter dated: 04-06-2025.

>◇◇◇*@*◇◇◇<

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises "M/s. Mari Gold International School, situated at Anchepalya, Kumbalagodu, Bengaluru-560 074. with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of "M/S. Mari Gold International School, had requested for the Fire Safety Compliance Report from our department. In this regard the above school building was inspected by Fire Station Officer, Sunkadakatte Fire Station on 10-06-2025 and submitted the report & recommended to issue Compliance Report.

Kaveri
PRINCIPAL
MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

S. S. S. S.
CHAIRMAN
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.




Under the above circumstance the Karnataka State Fire & Emergency Services Department is issuing the "Renewal Fire Safety Compliance Certificate" to " **M/s. Mari Gold International School, situated at Anchepalya, Kumbalagodu, Bengaluru-560 074** subject to proper maintenance of firefighting installations in the good working conditions and arrange for 40% of staffs/employees training within 03 months from the date of issue of this report.

In case the Fire prevention and Fire Fighting measures installed as per the recommendation of the department are not maintained in good working condition, if the evacuation measures are not properly followed and if any additional construction work is taken up in the building/premises, the Fire Safety Compliance Report deemed to be cancelled and necessary legal action will be initiated against the developer/management/tenant and also separate NOC has to be obtained from the department for the storage of chemicals, solvents, petroleum products(Diesel/Petrol), LPG, etc. in the premises/building.

"This Fire Safety Compliance Report is valid for Only Two Year from the date of issue and it is renewable".

Kaveri
MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

Yours faithfully,

District Fire Officer (Fire Prevention)
Karnataka State Fire & Emergency Services,
Sunkadakatte Fire Station,
Bengaluru-562 130


CHAIRMAN
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.

MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

Karnataka Fire and Emergency Services Department



Office of the District fire officer,
Jnanabharathi fire station
Bangalore University Premises, Bangalore – 560 056.
Ph No.080 – 22971614



No.51/CC/DFO/JBFS/2025.

Date:-27-06-2025.

TO,

The Principal
M/s. Marigold International School
Anchepalya, Kengeri Hobli
Bangalore-560074

9

Sir,

Sub: Issue of “Compliance Certificate” with respect to fire prevention, fire fighting and evacuation measures complied and maintained *M/s. Marigold International School, (Building-2), Anchepalya, Kengeri Hobli, Bangalore-560074*

Ref: 1. FSR Report No :51/FSR/DFO/JBFS/2025, Dated:26-06-2025
2. Your letter dated:-26-06-2025

* * * * *

With reference to subject above cited, ‘Fire Safety Recommendation’ was issued wide reference (1) to the premises maintained *M/s. Marigold International School, Anchepalya, Kengeri Hobli, Bangalore-560074* with an condition to fulfill the recommendations and compliance of the same within 3 months.


As per reference cited (2) above The management of *M/s. Marigold International School, (Building-2), Anchepalya, Kengeri Hobli, Bangalore-560074* had requested for the Fire Safety Compliance Certificate from our department.

The above mentioned educational building was inspected me on 27-06-2025 for issuing Compliance Certificate, the management of *M/s. Marigold International School, (Building-2), Anchepalya, Kengeri Hobli, Bangalore-560074* has complied all the recommendation communicated in Fire Safety Recommendation.

Kaveri

MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.


M. Jayade
MANAGER
MARIGOLD TRUST
“MARIGOLD SQUARE”, No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.




Under the above circumstances the Karnataka Fire & Emergency Services Department has Issued the '*Fire Safety Compliance Certificate*' of *M/s. Marigold International School, (Building-2), Ancephalya, Kengeri Hobli, Bangalore-560074* Subject to Proper maintenance of fire fighting installations in good working conditions and to arrange basic fire fighting training for employees at our R.A.Mundkur Fire & Emergency service academy, Bangalore and to renewal the compliance report for every two year.

This Fire Safety Compliance Certificate is valid till dated 26-06-2027 and it is renewable.

Yours faithfully.


District Fire Officer *28/6/25*
Jnanabharathi Fire Station
Bangaluru - 560 056


MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.


CHAIRMAN
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.

Karnataka Fire and Emergency Services Department



Office of the District fire officer,
Jnanabharathi fire station

Bangalore University Premises, Bangalore – 560 056.
Ph No.080 – 22971614



No.51/FSR/DF0/JBFS/2025.

Date. 26-06-2025.

To,

The Principal
M/s. Marigold International School
(Building- 2)
Anchepalya, Kengeri Hobli
Bangalore-560074

10

Sir,

Sub: Issue of **Fire Safety Recommendation** with respect of Fire prevention fire fighting and evacuation measures required at **M/s. Marigold International School,(Building-2),Anchepalya, Kengeri Hobli,Bangalore-560074**

Ref: Your letter dated:-24-06-2025

ANNEXURE-B

NBC-2016, Part-4, Table 7 (1) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

With reference to the subject cited above, I have inspected the premises of **M/s. Marigold International School,(Building-2), Anchepalya, Kengeri Hobli, Bangalore-560074**, on 25-06-2025 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the premises and the details as under:-

Details of the building / premises :-

01	Name and Address of the Applicant.	: The Principal M/s. Marigold International School (Building-2),Anchepalya, Kengeri Hobli,Bangalore-560074
----	------------------------------------	---

Kaveri

MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

Chandana
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.




02	Name and Address of the premises.	:	<i>M/s. Marigold International School (Building-2), Ancephalya, Kengeri Hobli, Bangalore-560074</i>
03	Name and address of the Building owner	:	<i>Dr. Ujwala N Jagadale Managing Trust M/s. Marigold International School (Building-2), Ancephalya, Kengeri Hobli, Bangalore-560074</i>
04	Number of buildings	:	One Building
05	Number of floors	:	Ground & 02 upper floors
06	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	01 entrance Lobby, 01 Registration Desk, Swimming area and Lockers
	1 st floor	:	Yoga & meditation Hall, 02 Class room
	2 nd floor	:	02 Badminton, 01 math Lab, 02 Class room
07	Height of the buildings:-	:	14.50 mtrs
08	Site area	:	17000 Sq mtrs .
09.	Built-up area of each floor:-		
	Ground floor	:	1226.32 Sq.mtrs
	1 st floor	:	1226.32 Sq.mtrs
	2 nd floor	:	1226.32 Sq.mtrs
10.	Total built-up area	:	3678.96 Sq.mtrs.
11.	Surrounding properties:-		
	East (Front)	:	10.00 mtrs wide chalegatta road
	West (Rear)	:	Railway track
	North (Side)	:	Parking yard
	South (Side)	:	Play Ground
12.	<u>Set-back area available around the building :-</u>		
	East (Front)	:	07.00 mtrs
	West (Rear)	:	04.00 mtrs
	North (Side)	:	07.00 mtrs
	South (Side)	:	07.00 mtrs
	Allowed setbacks (Open space) Should be maintained free from further obstruction/construction		

Kaveri

MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

Jagadale
CHAIRMAN

MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.



A. On inspection of this School/Collage premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No.(1)	Details (02)	Existing (03)	Recommendations (04)																					
1.	Accessibility to the premises	The premise is accessible from 10.00 mtrs wide Chalegatta road located on Eastern side The road is hardened to carry the Weight of 45,000 Kgs	Adequate.																					
2.	No. of entrances	02 Entrances with entry & Exit.	Adequate.																					
3.	Width of entry / exit	06.00 mtrs width one of eastern side and anther one of Northern side have been provided.	Adequate.																					
4.	Number of staircases Available	<table border="1"> <tr> <td>Nos. of staircases</td> <td>:</td> <td>02</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>01.70 mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 Cm</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 Cm.</td> </tr> <tr> <td>Nos. of riser per flight</td> <td>:</td> <td>12 No's</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>01.00 mtrs</td> </tr> <tr> <td>Head room clearance</td> <td>:</td> <td>02.50 Mtrs</td> </tr> </table>	Nos. of staircases	:	02	Width of staircases	:	01.70 mtrs	Width of treads	:	30 Cm	Height of risers	:	15 Cm.	Nos. of riser per flight	:	12 No's	Height of handrails	:	01.00 mtrs	Head room clearance	:	02.50 Mtrs	Complied
Nos. of staircases	:	02																						
Width of staircases	:	01.70 mtrs																						
Width of treads	:	30 Cm																						
Height of risers	:	15 Cm.																						
Nos. of riser per flight	:	12 No's																						
Height of handrails	:	01.00 mtrs																						
Head room clearance	:	02.50 Mtrs																						
5.	No. lifts and capacity.	01 no's : 06 passenger lift is installed in the building	Complied																					

Kaveri

MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

M. Redale
CHAIRMAN
"MARIGOLD TRUST"
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.



6.	Portable Fire extinguisher	30 No's of ABC fire Extinguisher of 06 Kgs Capacity, and 15 no's of Co ₂ fire Extinguisher of 4.5 Kgs Capacity each floor of every building have been provided.	Complied
7.	First aid Hose reel hose.	Hose Reel Hose system has been provided near the staircases. Each hose reel hose of min 19mm size and of adequate length to reach the farthest point of each floor have been provided shut off branch having a nozzle of 5mm size. The hose reel hose have been connected at each landing.	Complied
8.	Terrace Pump at the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Each Hose reel hose system have been connected to an Booster pump capable of delivering 450 LPM (Further the system should be connected to an alternative source of power supply)	Complied
9.	Terrace tank over respective tower terrace.	Each Hose reel hose system Have been connected to an over head tank of 10,000 ltrs capacity. (The water tank should be kept exclusively for firefighting).	Complied
10.	Public address system	Public address system with 2 way communication facility near the staircase landing with its console at the control room, located on the ground floor of Building have be provided.	Complied
11.	Escape routes	Escape routes and fire exits boards have been displayed at corridors or passages and appropriate places of the	Displayed.

Kaveri
MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

M. S. Prasad
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.



		building to guide the students and staff to safer places during emergency or fire.	
12.	Fire order (fire safety Plans)	A notice board indicating the details of actions to be taken in case of emergency have been displayed near each staircase landings with the telephone numbers of our Jnanabharathi Fire Station 080-22971614 or 101 or 112, and telephone numbers of nearest Ambulance Service.	Complied
13.	No Smoking board	COTPA Sec-4 direction No smoking area, Smoking is an offence board have been written in English and kannada both language shall be prominently displayed at inside the entry/exit of each floor.	Complied
14.	Fire siren	A fire siren has been installed in the premises to inform the inmates in the case of a fire emergency and evacuate the area.	Complied
15.	Fire fighting training	Not yet Trained	At least 40% of Teaching and non teaching staff should be got trained basic fire fighting at R.A. Mundkur Fire and Emergency Sevices Academy, Bannerughatta road, Bangalore.

Fire precautionary measures :-

- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustibile waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.

Kaveri

MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

D. Adate
CHAIRMAN
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 10
ITI Layout, 30th Main Road, Sarajewadi
Bangalore - 560 078.



- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is Issue of '**Fire Safety Recommendation**' to **M/s. Marigold International School, (Building-2), Anchepalya, Kengeri Hobli, Bangalore-560074** subject to condition and compliance of the above recommendations in column-4 of serial-B within 3 months and compliance to the undersigned.

Yours faithfully.

Kaveri
MARIGOLD INTERNATIONAL SCHOOL
ANCHEPALYA, BANGALORE - 560 074.

[Signature]
District Fire Officer *22/6/25*
Jnanabharathi Fire Station
Bengaluru - 560 056

[Signature]
CHAIRMAN
MARIGOLD TRUST
"MARIGOLD SQUARE", No. 17,
ITI Layout, 30th Main Road, Sarakki,
Bangalore - 560 078.